



ROCKLAND FIRE DEPARTMENT

P.O. BOX 542
360 Union Street
Rockland, Massachusetts 02370-0542



Scott F. Duffey, *Chief*
Thomas Heaney, *Deputy Chief*
Mary Ryan, *Executive Assistant*

Phone (781) 878-2123
Fax (781) 982-0302

NEST™ Smoke Detector/CO System Requirements

- Battery operated NEST™ Smoke/CO detectors are allowed for residential smoke detector coverage if the home or condominium:
 1. Was built prior to 1975
 2. Has not been substantially renovated
- Hardwired (120 volt) NEST™ devices are allowed in residences that were built or substantially renovated between 1975 and 2008
- Homes built after 2008 with a garage are required to have heat detectors. Currently, NEST™ does not manufacture a heat detector. Therefore, NEST™ systems do not meet the Massachusetts requirement for homes built or substantially renovated since 2008, that have attached garages.