

Monthly Operating Report

FEBRUARY 2023



Before



After

Rockland, MA WWTP





March 15, 2023

Mr. Chuck Heshion

Rockland Sewer Commission Chairman

587 Rear Summer Street

Rockland, MA 02370

RE: Rockland Wastewater Facility

Monthly Report—February 2023

Dear Mr. Heshion,

I have enclosed February's 2023 Monthly Operating Report (MOR) for the Veolia Operations and Maintenance contract.

Please contact me if you should you have any questions regarding this report.

Sincerely,

Rick Kotouch

Veolia Project Manager

CC:

Daniel Duross

Sherri Vallie

FEBRAURY 2023 MONTHLY OPERATING REPORT

1. SUMMARY:

The facility will be reporting **1** exceedance for the month of February 2023

- 1) There was **0** lost time / first aid injuries throughout the month
- 2) The facility treated a total of **82,380,000** Million Gallons. The average daily flow was **2.942** MGD
- 3) The total rainfall for this reporting period was **1.69"**
- 4) I&I Work is ongoing
- 5) **152** work orders were closed in February, with **6** as corrective maintenance work order and 3 were emergency call outs
- 6) Massachusetts general wastewater permit will begin April 1st.

2. STAFFING:

Current Employee Licenses as of 08/31/2022										
		Hoisting		Wastewater			NEWEA Collections			NEWEA Laboratory
Employee	Title	1C Forklift	1B Boom Truck & Forklift	3M	5C	7C	I	II	IV	I
Richard Kotouch	Project Manager					X			X	
Megan Kelly-Lynch	Asst. Project Manager	X				X				
Steven Butts	Lab Technician					X				X
Charles Amaral	Maintenance Foreman				X			X		
Garry Murrill	O&M Tech II				X			X		
Maxwell Jackson	O&M Tech I			X						
Cristian Ryan	Operator in Training									
Shaun Chaponis (Part Time Weekends)	O&M Tech II				X		X			



3. EMPLOYEE HEALTH AND SAFETY:

Throughout the COVID-19 (Coronavirus) pandemic in an attempt to continue to serve the Town of Rockland with reliable operations and protect the staff of the Rockland team, Veolia has implemented numerous procedures to ensure continuity of the operations. As the COVID-19 Delta variant and Omicron rates decrease, Veolia at the Rockland facility has downgraded to a Threat Level 0 guideline as follows: We ask all essential personnel, contractor's to stay home if they have Covid like symptoms or have been exposed to someone having Covid.

4 FLOWS AND LOADINGS:

4.0 FLOWS, PRECIPITATION, AND WEATHER

- The facility treated a total of 82,380,000 MG during the month. The daily average flow was **2.942** MGD. This was **1.116** MGD than the previous February monthly average, which was recorded at **4.058** MGD. The highest daily flow was recorded on February 1st as **3.910** MGD. The lowest daily flow was recorded on February 20th as **2.530** MGD.
- The highest **peak** flow was recorded on February 3rd as **4.830** MGD. The lowest instantaneous flow was **0.760** MGD, recorded on February 15th.
- A total of **1.69"** of precipitation was received at the facility. The highest single day precipitation total was recorded on February 22nd as **0.61"**
- The coldest day was February 4th at **-12°F**. The warmest day was February 3rd at **62°F**.



4.1 INFLUENT BOD AND TSS LOADING


ROCKLAND FLOW AND LOADINGS TRACKING						
Month/Yr	Inf. Flow	Inf BOD	Inf. TSS	Inf. Flow Mov. Avg.	Inf. BOD Mov. Avg.	Inf. TSS Mov. Avg.
	MGD	LBS	LBS	MGD	LBS	LBS
Mar '22	3.425	3,887	4,456	3.055	3,240	3,855
Apr '22	2.765	3,907	4,051	3.024	3,299	3,891
May '22	2.185	3,809	4,229	2.988	3,326	3,909
Jun '22	1.991	4,343	4,006	2.952	3,365	3,975
Jul '22	1.739	3,316	3,546	2.810	3,446	3,990
Aug '22	1.614	3,313	3,758	2.702	3,469	3,969
Sep '22	1.808	3,716	3,838	2.597	3,581	3,880
Oct '22	2.481	3,323	4,180	2.538	3,608	3,904
Nov '22	2.295	4,948	3,227	2.469	3,832	3,881
Dec '22	3.412	4,234	3,802	2.544	3,885	3,890
Jan '23	4.266	4,250	3,763	2.670	2,913	3,897
Feb '23	2.942	3,408	2,970	2.577	3,871	3,819

4.2 LIFT STATION FLOWS

The lift stations accounted for **10,470,840** gallons throughout the month, **13%** of the total plant flow. Please note that monthly lift station flow totals are purely estimates based off of pump run hours and estimated flow rates. Values are not intended to in any way be used as design capacity volumes for potential future rehab / replacement projects.

Total Flows for February 2023		
Station	Total Gallons	
Millbrook	1,234,440	
Summer	24,240	
Market	379,500	
John Burke	145,200	
Lincoln, Forest	1,482,600	
Wheeler	137,160	
Woodsbury	1,405,800	
OCW, HN, HS	5,572,800	
Butternut	89,100	
Total:	10,470,840	

February 2023 Lift Stations Daily Flows




Lift Station Monthly Average Daily Flows (GPD)

Month	Millbrook	Summer	Market	John Burke	Lincoln	Forrest	Wheeler	Woodsbury	Old Country Way	Hingham North	Hingham South	Butternut
	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	
Mar '22	31,459	929	15,677	1,881	3,232	42,339	703	49,355	59,206	157,994	182,555	Old System
Apr '22	33,156	920	16,150	2,456	2,600	42,980	834	46,620	57,960	151,920	172,800	
May '22	31,738	937	15,677	2,655	2,400	39,155	726	45,348	53,110	142,142	155,380	
Jun '22	33,073	994	15,640	1,872	2,520	41,300	828	45,060	53,900	144,540	159,480	
Jul '22	27,975	1,223	14,318	1,644	2,110	36,581	586	32,865	51,755	73,335	273,484	
Aug '22	31,459	1,076	15,581	2,145	2,439	40,442	703	38,265	44,100	134,843	113,574	3,475
Sep '22	29,628	976	15,400	1,816	2,389	45,990	732	45,660	42,350	134,460	141,480	2,040
Oct '22	38,114	1,092	14,758	1,386	2,419	49,181	743	43,897	46,810	149,807	273,484	3,870
Nov '22	35,316	1,112	14,450	1,840	2,460	46,410	918	40,740	46,970	142,920	165,599	2,640
Dec '22	47,052	888	14,750	2,480	2,580	56,070	786	57,780	60,155	169,200	199,974	3,658
Jan '23	47,052	888	14,750	2,480	2,580	56,070	786	57,780	60,155	169,200	199,974	3,658
Feb '23	44,087	866	13,554	5,186	3,000	52,950	4,899	50,207	58,650	164,565	199,029	3,182
Average	35,842	992	15,059	2,320	2,561	45,789	1,104	46,131	52,927	144,577	186,401	3,218

5.0 SOLIDS HANDLING

The BFP was operated a total of **134.25** hours this month and a total of **355,441** gallons were processed producing **96.05** Wet Tons of sludge that was hauled from the facility. The average BFP feed percent solids were **1.59%** and the BFP Cake average percent solids were **18.77%**. The sludge processing Dry Tons conversion sheet is attached to this report.



Date	BFP Run Hours	Total Digester Feed	Total BFP Feed	Polymer Used	Actual Sludge Weight	Average Press Feed Total Solids	Average Cake Total Solids	Sludge Pick Up	Grit Removed
	HRS	Gal.	Gal.	Gal.	Wet Tons	%	%	Dumpster	Tons
Mar '22	533.0	412,533	477,919	136.1	128.9	1.79	18.32	7.00	
Apr '22	133.8	422,314	410,793	123.4	123.0	2.66	19.69	6.00	
May '22	174.3	468,083	571,658	154.1	124.7	1.89	21.14	8.00	
June '22	151.3	439,371	530,756	132.9	113.3	2.26	21.92	6.00	
July '22	137.5	524,233	475,614	119.6	89.8	2.04	22.05	5.00	
Aug '22	152.6	626,023	477,850	132.8	126.8	2.15	23.45	7.00	
Sep '22	140.6	550,718	436,908	118.4	110.0	2.46	24.43	7.00	
Oct '22	154.3	528,474	478,215	142.4	114.0	2.48	22.86	6.00	
Nov '22	130.0	325,410	393,155	90.4	89.6	1.96	22.45	5.00	
Dec '22	150.5	403,272	472,903	115.2	121.6	1.73	20.27	6.00	
Jan '23	129.2	324,034	377,362	119.2	89.4	1.72	19.24	6.00	
Feb '23	134.3	320,572	355,441	115.5	96.1	1.59	18.77	6.00	
Annual Total	2,121	5,345,037	5,458,574	1,500	1,327	*****	*****	75	0.00
Avg.	177	445,420	454,881	125	111	2.06	21.22	6.3	*****

6.0 ENVIRONMENTAL COMPLIANCE

6.1 REGULATORY REPORTING

1. The OSHA 300A was posted on 2/1/2023
2. Annual Biosolids Sludge Report (503B) was submitted online on 2/6/2023
3. Annual Tier II Report was submitted online on 2/13/2023
4. The EPA and MADEP February NETDMR was submitted on the CDX website on 3/9/2023

6.2 NPDES COMPLIANCE

The facility will be reporting (1) exceedance(s) for the month of February 2023

Date	Plant Flow	BOD	BOD	TSS	TSS	NH3	Total P	Ph	E. Coli Coliform	Aluminum	Copper	Dissolved Oxygen	Limits	Monthly Avg.	Weekly Avg.	Daily Max
	MGD	Mg/L	Lbs./Day	Mg/L	Lbs./Day	Mg/L	Mg/L	Ph	CFU/100 ml	Ug/L	Ug/L	Mg/L	BOD			
Wed, Feb 1	3.910							7.18					Oct. 1 - April 30	20 Mg/L 417 lbs/day	20 Mg/L 417 lbs/Day	30 Mg/L 626 lbs/Day
Thur, Feb 2	3.780	7.9	249	7	230	2.70	0.31	7.13					May1 - Sept. 30	6 Mg/L 125 lbs/Day	6 Mg/L 125 lbs/Day	10Mg/L 209 lbs/day
Fri, Feb 3	3.600							7.12					TSS			
Sat, Feb 4	3.590							6.94					Oct. 1 - April 30	20 Mg/L 417 lbs/Day	20 Mg/L 417 lbs/Day	30 Mg/L 626 lbs/Day
Sun, Feb 5	3.500							6.88					May1 - Sept. 30	10 Mg/L 209 lbs/Day	10 Mg/L 209 lbs/Day	15Mg/L 313 lbs/day
Mon, Feb 6	3.170							7.39	68				NH3			
Tue, Feb 7	3.100	4.0	103	4.7	122	0.55	0.28	7.61	54	17	6.4		Oct.1 - Mar. 31	3.3 Mg/L	3.3 Mg/l	5.7 Mg/L
Wed, Feb 8	2.990							7.33	123				Apr. 1 - May 31	2.5 Mg/L	2.5 Mg/l	5.7 Mg/l
Thur, Feb 9	2.960	3.2	79	4.7	116	0.10		7.55					June1 - Sept. 30	1.0 Mg/L	1.0 Mg/L	1.5 Mg/L
Fri, Feb 10	2.820							7.30					Total Phpsphorus			
Sat, Feb 11	2.830							7.26					Apr.1 - Oct.31	0.2 Mg/L	*****	*****
Sun, Feb 12	2.940							7.28					Nov. 1 - Mar. 31	1.0 Mg/L	*****	*****
Mon, Feb 13	2.760							7.39	219				Ph			
Tue, Feb 14	2.620	2.0	44	4.7	103	0.16	0.19	7.25	50				6.5 - 8.3			
Wed, Feb 15	2.630							7.21	129				Fecal			
Thur, Feb 16	2.640	2.4	53	3.3	73	1.30		7.23					*****	200 CFU/100ml	*****	400 CFU/100ml
Fri, Feb 17	2.560							6.77					Aluminum			
Sat, Feb 18	2.600							6.80					*****	88 ug/l	*****	*****
Sun, Feb 19	2.740							7.32					Copper			
Mon, Feb 20	2.530							7.41	68							
Tue, Feb 21	2.560	4.9	105	11.0	235	0.93	0.43	7.50	40							
Wed, Feb 22	2.560							7.49	7							
Thur, Feb 23	2.820	3.7	87	4.0	94	0.31		7.44								
Fri, Feb 24	2.810							7.41								
Sat, Feb 25	2.860							7.41								
Sun, Feb 26	2.980							7.32								
Mon, Feb 27	2.720							7.40	395							
Tue, Feb 28	2.800	4.6	107	7.3	170	0.93	0.44	7.57	25							
Daily Max	3.910	7.90	249.05	11.00	234.85	2.70	0.44	7.61		*****	*****	*****	May 1 - Sept. 30	> 7.4 mg/L		
Daily Min.	2.530	*****	*****	*****	*****	*****	*****	6.77	*****	*****	*****	*****	Plant Flow			
Month Avg.	2.942	4.09	103.38	5.88	142.88	0.87	0.33	7.28		17	6.4	*****	2.5 MGD			


7.0 ENERGY CONSUMPTION

7.1 ELECTRICAL OVERVIEW


The department used a total of **142,112 KWH** for the month of February 2023. Of this total, the lift stations accounted for **12%**, using **16,712 KWH**. The Main Plant accounted for the remaining **125,400 KWH**.

The KWH/ MG treated was **1,522** for the month, which is **7%** lower than the previous 12-month average of **1,639 KWH/MG**. The KWH/Lb. BOD Removed was **1.36 KWH/Lb.** for the month, which is **23%** higher than the previous 12-month average of **1.05 KWH/Lb.**

Monthly Lift Station KWH														
Month	Hingham North	Hingham South	Spruce	Butternut	Old Country Way	Market	Woodsbury	Lincoln	Forest	Wheeler	Summer	Milbrook	John Burke	Total
Mar '22	2,995	5,100	246	434	1,353	851	1,353	283	1,915	58	67	1,524	236	16,322
Apr '22	3,149	5,000	215	161	1,332	964	1,332	280	1,809	72	69	1,562	185	15,055
May '22	2,429	4,100	111	58	930	667	930	176	1,418	57	61	1,256	116	12,380
June '22	2,540	4,300	109	63	853	347	892	168	1,371	59	74	1,234	113	12,123
July '22	2,119	2,900	110	49	741	337	685	134	1,202	49	69	832	89	9,326
Aug '22	2,293	3,200	102	54	871	334	820	153	1,337	54	68	967	91	10,344
Sept '22	2,094	2,900	110	48	807	348	928	172	1,269	48	56	1,015	82	9,877
Oct '22	2,943	4,100	195	73	952	887	1,308	260	1,942	69	80	1,325	142	14,276
Nov '22	2,907	4,600	218	66	1,184	832	1,240	308	2,043	63	67	1,734	207	15,469
Dec '22	3,575	6,100	156	83	1,427	957	1,841	352	2,515	63	63	2,026	263	19,421
Jan '23	3,577	6,500	145	90	1,802	924	1,848	341	2,466	123	62	1,863	308	20,049
Feb '23	3,039	5,000	141	70	1,281	862	1,440	325	2,187	227	59	1,749	332	16,712
Average	2,805	4,483	155	104	1,128	693	1,218	246	1,790	79	66	1,424	180	14,280



Monthly Energy Consumption										
Month	Plant Average Daily Flow (NO HFMP)	Plant Total Influent Flow	Plant KWH (Total Billed)	KWH/MG Treated (Plant)	Plant Lbs BOD Removed	KWH/Lb BOD Removed (Plant)	Off Peak Demand (Plant)	Peak Demand (Plant)	Total Lift Station KWH	Total KWH (Plant & Stations)
	MGD	MG	KWH	KWH/MG	Lbs	KWH/Lb	KW	KW	KWH	KWH
Mar '22	3.43	106.19	122,400	1,153	117,284	1.04	222	222	16,322	138,722
Apr '22	2.77	82.96	123,000	1,483	115,947	1.06	198	204	15,055	138,055
May '22	2.19	67.74	123,000	1,816	116,352	1.06	183	198	12,380	135,380
June '22	1.99	59.74	114,900	1,923	129,049	0.89	189	201	12,123	127,023
July '22	1.74	53.9	106,800	1,981	101,883	1.05	198	216	9,326	116,126
Aug '22	1.61	50.02	123,300	2,465	101,859	1.21	177	195	10,344	133,644
Sep '22	1.81	54.23	105,900	1,953	110,510	0.96	186	210	9,877	115,777
Oct '22	2.48	76.91	104,700	1,361	101,712	1.03	195	201	14,276	118,976
Nov '22	2.3	68.86	124,800	1,812	146,152	0.85	186	213	15,469	140,269
Dec '22	3.36	104.19	146,400	1,405	127,264	1.15	243	258	19,421	165,821
Jan '23	4.08	126.55	134,400	1,062	126,998	1.06	252	258	20,049	154,449
Feb '23	2.94	82.38	125,400	1,522	92,522	1.36	213	210	16,712	142,112
Average	2.56	77.81	121,250	1,661	115,628	1.06	204	216	14,280	135,530



8.0 MAINTENANCE

8.1 WORK ORDER OVERVIEW

WO Type	Total This Month	Total This Year
Preventative Maintenance	152	318
Corrective Maintenance	6	38
Emergency Call Outs Total	3	9

8.2 SIGNIFICANT CORRECTIVE WORK ORDERS FOR THE MONTH

CM Description	WO #
23414	EIS replaced modem for SCADA
23415	Sounder Systems Replacing the fire alarms in the main building

8.3 EMERGENCY CALL OUTS FOR THE MONTH

Type	Total this Month	Total this Year
Sewer Back Up / Collection System	4	6
Pump Station	1	5
Plant	1	3
Odor	0	0
Power Outages	1	1
Total:	7	15

8.4 INSPECTIONS / ANNUAL PMS COMPLETED DURING THE MONTH

1. All pump station alarms checked
2. Spruce probe cleaned weekly
3. Eye wash inspections completed weekly
4. Fire extinguisher inspections completed monthly
5. Annual UST Inspection for Digester Boiler and Plant Generator

8.5 COLLECTION SYSTEM AND IPP ASSISTANCE PERFORMED BY VEOLIA

COLLECTION SYSTEM ASSISTANCE:

Type	Total This Month	Total This Year
Sewer Inspection / Tie-Ins	0	0
Sewer Location mark Outs	41	122
Sewer Back Up	4	4

8.6 WORK ORDER STATISTICS

There were **83.50** total reported maintenance hours during the month. Of this total, outside contractors accounted for 29% with **24** hours recorded.

