Comprehensive Wastewater Management Plan Public Hearing

September 6, 2023

Kevin Olson, PE Adam Higgins, PE





Presentation Overview

Project Team

Reasons for Comprehensive Wastewater Management Plan (CWMP)

Phase 1 Overview

Phase 2 Overview

Phase 3 Overview

Funding/Financing

Questions & Discussion



Project Team - Town of Rockland



Board of Sewer Commissioners

Chuck Heshion

Daniel E. DuRoss

Sherri Vallie



Project Team - Veolia



Veolia Staff, WWTP and PS Operations

Rick Kotouch

Megan Lynch

Project Manager

Asst. Project Manager



Project Team - Wright-Pierce Engineers



Kevin Olson kevin.olson@wright-pierce.com 978.416.8900



Adam Higgins adam.higgins@wright-pierce.com 978.416.8020



Reasons for the CWMP

Town-Wide Planning

- 20-year period
- Unsewered areas
- Proposed developments
- Key areas of protection and environmental concern



Wastewater Collection System

- Existing pipes
- Pump stations
- Capacity
- I/I Control



Wastewater Treatment Plant

- New NPDES Permit
- Aging equipment
- Current building code requirements
- Capacity



Project Financing

- 0/2 % SRF Loan
- 20 or 30-year Loan
- Other requirements

Town, Veolia, EPA and MassDEP involvement throughout project: Workshops, Meetings, Reviews



Comprehensive Wastewater Management Plan Approach

Phase 1 – Existing Conditions,
Problem Identification and Needs
Assessment

Phase 2 – Alternatives Identification and Screening

Phase 3 – Detailed Evaluation of Alternatives and Recommended Wastewater Management Plan



Rockland's Overall CWMP Approach

1

Phase 1 – Assessment of Existing Conditions

2


Phase 2 – Alternatives Identification and Screening

3

Phase 3 – Evaluation of Short-Listed Alternatives in Phase 2 and Develop a Recommended Wastewater Management Plan




Previous Planning/Studies/Projects




WWTP Assessment

WP evaluated the WWTP and provided recommendations to improve the WWTP, including secondary and tertiary treatment solutions. Completed Spring 2021.



Infiltration/Inflow (I/I) and Sewer System Evaluation Survey (SSES)

I/I and SSES work previously completed and ongoing. 2021 SSES included recommendations to reduce I/I. Sewer rehabilitation project and flow monitoring completed in Summer 2023



Master Plan of 2030

The Town of Rockland's roadmap for planning from 2020 to 2030 to achieve the Town's long-term goals and objectives for the community.




Phase 1 CWMP



- Existing conditions
 - Town metrics
 - Planning area
 - Wastewater collection & treatment
 - Water treatment & distribution
- Develop Study Areas
- Perform wastewater needs assessment




Existing Wastewater Collection System





Onsite Subsurface Wastewater Disposal Systems




- Few residents serviced by onsite systems
- Septic systems typically include
 - Septic tank
 - Distribution box
 - Leach/drain field
- Cost-effective solution
 - Need
 - Ideal soils
 - Adequate depth to groundwater/bedrock
 - Spatial parcel sizes
 - Separation from drinking water supplies



Determination of Study Areas for Non-Sewered Areas

7 Study Areas

- Areas determined by
 - Environmental criteria
 - Topography
 - Major roads
- Parcels removed
 - Protected open space
 - Non-developable area (wetlands, etc.)
 - Town-owned land
 - Planned large developments






Scoring of Study Areas

Stud	y Area	Primary Criteria (Ranking 0 to 10)						Secondary Criteria (Ranking 0 to 5)							ng
No.	Name	Soils Drainage Class	Depth to Water Table	Depth to Bedrock	Parcel Sizes	Private Wells	Primary Total	Drinking Water Protection District	Areas Within Regulated Setbacks	Flood Plains	Priority/Established Habitat Areas	Historic District	Secondary Subtotal	Total Score	Study Area Ranking
1	Weymouth Street	6	8	3	1	0	18	3	2	4	0	0	9	27	High
2	Pond Street	5	4	0	1	0	10	5	3	4	0	0	12	22	Avg
3	VFW	4	3	0	3	0	10	3	3	0	0	0	6	16	Low
4	Liberty Street	5	5	0	1	2	13	0	2	2	0	0	4	17	Low
5	East Water Street	8	7	0	1	0	16	0	2	2	0	0	4	20	Avg
6	Summer Street	8	6	0	0	0	14	0	2	3	0	0	5	19	Low
7	Industrial Way	7	6	0	0	0	13	3	2	4	0	0	9	22	Avg



Existing Wastewater Infrastructure

- Approximately 57 miles of gravity sewer and 4 miles of force main
- 13 pump stations
- Serves approximately 18,000 customers from Rockland and small parts of Abington
- 1 WWTP with NPDES Permit flow limit of 2.5 MGD with new strict seasonal TP Limit of 0.1 mg/L





Collection System Evaluation










Pump Stations Evaluation









WWTP Evaluation























Parameter	Limitation	Sample Frequency
BOD ₅ Removal	>85%	1/month
TSS removal		
Escherichia coli	Average Monthly = 126 cfu/100 mL Maximum Daily = 409 cfu/100 mL	3/week, grab
Total Phosphorous (TP)	Average Monthly: Apr 1 - Oct 31 = 0.1 mg/L Nov 1 - Mar 31 = 1.0 mg/L Maximum Daily = Report	2/week, 24-hour composite 2/week, 24-hour composite
Dissolved Oxygen	> 7.4 mg/L	1/day, grab
Total Copper	Average Monthly = 12 µg/L Maximum Daily = 19 µg/L	1/month, 24-hour composite
Total Aluminum	Average Monthly = 87.2 µg/L Maximum Daily = Report	1/month, 24-hour composite
PFAS compounds	Maximum Daily = Report	1/quarter composite







EPA Order

- Reduce flows to WWTF
 - I/I reduction
 - Peak flow reduction
- TP Compliance
- Evaluate "Flow Shedding" options
 - Groundwater discharge
- Alternative Surface Water Discharge

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 1

IN THE MATTER OF)	DOCKET NO. CWA-AO-R01-FY22-05
)	
Town of Rockland, Massachusetts)	FINDINGS OF VIOLATION
NPDES Permit No. MA0101923)	
)	AND
Proceedings Under Sections 308(a) and)	
309(a)(3) of the Clean Water Act,)	ORDER FOR COMPLIANCE
33 U.S.C. §§ 1318(a) and 1319(a)(3))	
55 10 10 10 10 10 10)	

STATUTORY AUTHORITY

The following FINDINGS are made, and ORDER issued pursuant to Section 308(a) and Section 309(a)(3) of the Clean Water Act, (the "Act"), 33 U.S.C. §§ 1318, 1319(a)(3). Section 309(a)(3) of the Act grants the Administrator of the U.S. Environmental Protection Agency ("EPA") the authority to issue orders requiring persons to comply with Sections 301, 302, 306, 307, 308, 318 and 405 of the Act and any permit condition or limitation implementing any of such sections in a National Pollutant Discharge Elimination System ("NPDES") permit, issued under Section 402 of the Act, 33 U.S.C. § 1342. Section 308(a) of the Act, 33 U.S.C. § 1318(a), authorizes EPA to require the submission of any information required to carry out the objectives of the Act. These authorities have been delegated to the EPA Region 1 Administrator, and, in turn, to the EPA, Region 1 Director of the Enforcement and Compliance Assurance Division (the "Director").



Rockland's Overall CWMP Approach


Phase 1 – Assessment of Existing Conditions

Phase 2 – Alternatives Identification and Screening

Phase 3 – Evaluation of Short-Listed
Alternatives in Phase 2 and Develop a
Recommended Wastewater Management
Plan



Phase 2 Goals




- Evaluate wastewater management alternatives for high needs area 1
 - Onsite systems
 - Innovative/Alternative (I/A) Systems
 - Decentralized WWTF
 - Collection system extension
- Evaluate groundwater discharge locations
- Shortlist alternatives to move into Phase 3



High Needs Area 1 - Weymouth Street

- 4 Parcels
- Northern part of Town
- High groundwater
- Near existing sewer system and Union Point Development





Needs Area Grading Results

	Primary Criteria (Scoring from 0 to 10)							Secondary Criteria (Scoring from 0 to 5)					
Treatment Alternative	Level of Treatment	Nutrient Treatment	Land/Site Requirements	Capital / Construction Costs	Ease of Operation	Primary Criteria Subtotal	Public Acceptance	Regulatory	Legal	O&M Costs	Environmental	Secondary Criteria Subtotal	Total Score
On-site													
Conventional Septic Systems	8	9	5	1	2	25	0	1	0	1	4	6	31*
I/A Systems	6	6	4	3	4	23	1	2	1	2	3	9	32*
Decentralized													
Shared Septic Systems	8	9	6	4	3	30	3	1	2	2	4	12	42
Shared I/A Systems	6	6	7	5	5	29	3	2	2	3	3	13	42
Decentralized WWTF	1	2	8	7	6	24	1	3	3	4	1	12	36*
Collection Syste	em Extensio	ns											
Town of Rockland	0	2	2	3	1	8	1	5	5	2	2	15	23*



Needs Area Flow Estimates

Study Area	Potential Existing Flow		Estimated Build-out Flov	v ⁺	Estimated Flow from I/I		Total Future Flow Estimate
1 – Weymouth Street	0	+	34,800	+	1,100	=	35,900



Groundwater Discharge Alternatives

- Open Space
- Not protected
- Not wetland
- Town-owned is best





Rockland's Overall CWMP Approach

Phase 1 – Assessment of Existing Conditions

Phase 2 – Alternatives Identification and Screening

Phase 3 – Evaluation of Short-Listed
Alternatives in Phase 2 and Develop a
Recommended Wastewater Management
Plan



Shortlisted Alternatives for Needs Area 1



Shortlisted Alternatives


- Septic systems
- I/A systems
- Collection system extension
- Decentralized WWTF

Needs Area Description

- Northeastern part of Rockland
- 22 acres, 4 parcels
- Varies between very good and very poor soils, and wetlands



Collection System Extension for Needs Area 1





Present Worth Cost Estimates

Summary of Cost Estimates for Needs Area 1

	Treatment Alternatives						
Cost Estimate	Septic System	Innovative/Alternative System	Collection System Extension				
Initial Capital Cost	\$ 0	\$ 0	\$1,560,000				
Present Worth of Future Capital Costs	\$ 309,000	\$ 380,000	-				
Present Worth of O&M Costs	\$ 20,000	\$ 190,000	\$ 0				
Total Present Worth	\$ 329,000	\$ 570,000	\$ 1,560,000				



Collection System I/I Control Plan



- Work completed to date
- I/I Control Plan recommendations
 - Phase 1 Sewer System Evaluation Survey (SSES) Tasks ongoing
- Recommended schedule
- Cost estimate



I/I Control Plan Cost Estimate & Schedule

Fiscal Year	Calendar Year/Month	Project Name	Scope	Subarea(s)	Sewer Length (If)	Manhol es	Estimated Cost ²
FY 2023	Spring 2023	Year 1 Program	Town-wide metering program and GIS- based Depth-to-Groundwater Analysis	-	-	-	\$150,000
Phase 1							
FY 2024	Spring 2024	Year 2 Infiltration	Manhole inspections and television inspections	-	34,000	170	\$150,000
FY 2025	Spring 2025	Year 3 Infiltration	Manhole inspections and television inspections	-	34,000	170	\$155,000
FY 2026	Spring 2026	Year 4 Infiltration	Manhole inspections and television inspections	-	34,000	170	\$160,000
FY 2027	Summer 2026 – Spring 2027	Year 2 to 4 Inflow	Smoke testing, dye testing/flooding with TV, and building inspections	-	102,000	-	\$200,000
FY 2028	Design – Summer 2027 Bid – Fall/Winter 2027 Construction – Spring 2028	Year 2 to 4 Rehabilitation	Sewer System Rehabilitation – cost effective and structural defective rehabilitation	-	TBD	TBD	\$1,500,000 ¹



Infiltration
Inflow
Rehab/Construction

I/I Control Plan Cost Estimate & Schedule

Fiscal Year	Calendar Year/Month	Project Name	Scope	Subarea(s)	Sewer Length (If)	Manholes	Estimated Cost ²
Phase 2							
FY 2029	Spring 2029	Year 5 Infiltration	Manhole inspections and television inspections	-	34,000	170	\$170,000
FY 2030	Spring 2030	Year 6 Infiltration	Manhole inspections and television inspections	-	34,000	170	\$175,000
FY 2031	FY 2031 Spring 2031 Year Infiltra		Manhole inspections and television inspections	-	34,000	170	\$180,000
FY 2032	Summer 2031 – Spring 2032	Year 5 to 7 Inflow	Smoke testing, dye testing/flooding with TV, and building inspections	-	102,000	-	\$220,000
FY 2033	Design – Summer 2032 Bid – Fall/Winter 2032 Construction – Spring 2033	Year 5 to 7 Rehabilitation	Sewer System Rehabilitation – cost effective and structural defective rehabilitation	-	TBD	TBD	\$1,500,000 ¹

^{1.} Estimated costs includes construction and engineering


^{2.} Estimated unit cost is based on 3-4% increase from previous year

Inflow Rehab/Construction	Infiltration
Rehab/Construction	Inflow
	Rehab/Construction



Groundwater Discharge - Options

- Met with Stakeholders
- Shortlisted sites
 - Union Point (reduced in size)
 - Jefferson School
 - Esten School Land
 - Beech Hill Landfill
- Reduced site size with soil info






Groundwater Discharge - Effluent Disposal

Site Name	Parcel Size (acres)	Usable Disposable Area (acres)	Disposal Capacity (gpd)			
		/ irea (aeres)	1.5 gpd/sq ft	4 gpd/sq ft		
Beech Hill Landfill	16	1.9	124,100	331,100		
Esten School	19	13	849,400	2,265,100		
Jefferson School	6.5	3.8	248,300	662,100		
Union Point	63	42	2,744,300	7,318,100		




<u>Groundwater Discharge – Effluent Disposal: Union Point</u>






Groundwater Discharge - Effluent Disposal: Jefferson School






Groundwater Discharge - Effluent Disposal: Esten School





Groundwater Discharge - Effluent Disposal: Beech Hill Landfill





Groundwater Discharge - Portion of WWTP Flow Costs

	1.1 MGD Capacity	2.7 MGD Capacity	0.12 MGD Capacity	0.25 MGD Capacity	0.85 MGD Capacity
Site	Unio	on Point	Beech Hill Landfill	Jefferson School	Esten School
Effluent Disposal Cost (\$)	\$10,700,000	\$25,700,000	\$1,800,000	\$2,900,000	\$8,400,000
Rockland WWTP Secondary Upgrades Costs (\$)	\$16,000,000	\$16,000,000	\$16,000,000	\$16,000,000	\$16,000,000
Sewer Routing Cost (\$)	\$18,500,000	\$18,500,000	\$15,000,000	\$6,100,000	\$1,900,000
Total Costs	\$45,200,000	\$60,200,000	\$32,800,000	\$25,000,000	\$26,300,000



Groundwater Discharge - Flow Shedding

Forest Street Pump Station

- Rated capacity of 400 gpm
- 576,000 gpd peak flow
- Average daily flow shed of 240,000 gpd


Hingham North Pump Station

- Rated capacity of 1,000 gpm
- 1,440,000 gpd peak flow
- Average day flow shed of 686,000 gpd

Combination of both

- 926,000 average gpd shed
- 1,000 35,000 gpd additional from Needs Area 1






Groundwater Discharge - Decentralized WWTF

Decentralized WWTF

- 0.5-1 MGD (larger for Union Point developer flows)
- Receive flows from Forest Street and/or Hingham North Pump Station
- Approximately 1 acre needed for facility
- Biological treatment
 - Membrane Bioreactors (MBR), Sequencing Batch Reactors (SBR), or Amphidrome

Union Point Disposal Site

 2.7-7.3 MGD disposal capacity based on loading rates from 1.5-4 gpd/SQFT







Groundwater Discharge - Decentralized WWTF Costs, Union Point

	Forest Street PS Shedding	Hingham Street, North PS Shedding	Both Pump Stations
Effluent Disposal Cost (\$)	\$5,900,000	\$22,200,000	\$31,100,000
Decentralized WWTF (\$)	\$26,500,000	\$46,300,000	\$56,500,000
Sewer Routing Cost (\$)	\$3,300,000	\$6,700,000	\$10,000,000
Total Costs	\$35,700,000	\$75,200,000	\$97,500,000



AHO Revise slide

Adam Higgins, 2023-09-01T18:22:58.329


Pump Stations Evaluation



- Evaluated all 13 pump stations
 - Condition assessment in Phase 1
 - Developed improvements/recommendations
- Developed a capital improvement plan with costs over 20-year planning period
 - Aggressive schedule based on age of station/equipment
 - Likely going to replace equipment as it fails so Town can focus on I/I and WWTP projects



Rockland Pump Stations





Rockland Pump Station Cost Estimates

Pump Station Name	Type Capacity (ea.) Pump H		Pump Horsepower	Year Constructed / Upgraded	Recommended Project Cost		
Forest Street	Submersible	400 gpm	29	1999	\$964,000		
Lincoln Road	Submersible	100 gpm	7.5	1999	\$618,000		
Wheeler Avenue	Submersible	30 gpm	3	1999	\$1,163,000		
Summer Street	Submersible	40 gpm	2	1999	\$1,170,000		
John Burke Drive	Submersible	40 gpm	2	1999	\$1,163,000		
Hingham Street - North	Submersible	1,000 gpm	20	2002	\$1,628,000		
Hingham Street - South	Submersible	1,800 gpm	100	2002	\$1,784,000		
Market Street	Submersible	250 gpm	7.5	1994	\$864,000		
Woodsbury Road	Submersible	300 gpm	15	1994	\$786,000		
Millbrook Drive	Submersible	180 gpm	15	2000	\$765,000		
Old Country Way	Submersible	350 gpm	7.5	1980	\$765,000		
Spruce Street	Submersible	100 gpm	5	2024	\$615,000		
Butternut Lane	Submersible	100 gpm	5	2022	\$618,000		



Pump Stations Capital Improvement Plan

Pumping Station		Plan Yea	r																		
	Total Est. Costs Per	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	Station	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	2044
Forest Street	\$964,000				\$964,000																
Lincoln Road	\$618,000				\$618,000																
Wheeler Avenue	\$1,163,000			\$1,163,000																	
Summer Street	\$1,170,000			\$1,170,000																	
John Burke Drive	\$1,163,000			\$1,163,000																	
Hingham Street - North	\$1,628,000					\$1,628,000															
Hingham Street - South	\$1,784,000					\$1,784,000															
Market Street	\$864,000		\$864,000																		
Woodsbury Road	\$786,000		\$786,000																		
Millbrook Drive	\$765,000				\$765,000																
Old Country Way	\$765,000	\$765,000																			
Spruce Street	\$615,000																			\$615,000	
Butternut Lane	\$618,000																			\$618,000	
Total for Year	\$13,015,000	\$765,000	\$1,650,000	\$3,496,000	\$2,452,000	\$3,412,000	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,240,000	\$0



<u>WWTP - Scope of Improvements</u>



Plant evaluation recommended improvements:

- New Screening and Grit Facility
- Influent Pump Station Modifications
- Primary Clarifier Modifications
- Secondary System Modifications
- Secondary Clarifier Modifications
- Tertiary System and Building
- Chemical Building
- Chlorine Contact Tanks and Effluent Pump Station
- Sludge Storage tanks
- Administration Building
- Garage and Electrical Building
- General



WWTP Recommended Improvements Cost Estimate

Project Component	Cost
Civil	\$1,379,000
Architectural	\$2,993,000
Structural	\$2,767,000
Process	\$11,063,000
HVAC/Plumbing	\$1,057,000
Instrumentation	\$1,085,000
Electrical	\$5,416,000
Specials	\$370,000
Construction Factors	\$4,727,000
Subtotal	\$30,858,000
Design Contingency	\$6,172,000
Construction Contingency	\$2,190,000
Inflation To Midpoint of Construction	\$6,728,000
Estimated Construction Cost	\$45,948,000
Engineering Services	\$8,752,000
Materials Testing	\$219,000
Legal/Administrative	\$428,000
Financing	\$837,000
Total Project Cost	\$56,163,000*

Recent bidding and construction climate has led to increased project costs and high inflation – planning value of \$72 million is more realistic



WWTP Typical Schedule

Milestone	Timeline*
Appropriate Engineering Funds for Design	Annual Town Meeting, May 2023
Preliminary Design (30%)	8 months, following Notice-to-Proceed
Preliminary Design Begins	August 2023
MassDEP SRF Project Evaluation Form (PEF) Submitted	August 2023
MassDEP SRF Intended Use Plan (IUP) Notification Draft	January 2024
Final IUP	1 month
Final Design & Permitting	12-14 months, beginning after Preliminary Design
Appropriate Construction Funds	Annual Town Meeting, May 2024
SRF Application Submission (90% Design)	By October 15, 2024
MassDEP Project Approval Certificate (PAC)	By December 31, 2024
100% Design and Permitting Complete	December 2024
Bidding	4 months, after 100% Design complete
Prequalification of GCs and Subs	January 2025 (2 months)
Filed Sub-bids	March 2025 (4 weeks)
GC Bids	April 2025 (6 weeks)
Construction*	30 months, beginning after GC selected and NTP
Contractor Notice-to-Proceed	By June 30, 2025
Substantial Completion	December 2027
Final Completion	February 2028
One-Year Warranty Period	December 2028



^{*}Extended construction period expected based on lead times for equipment such as generator, MCCs, switchgear, etc.

WWTP - Design Build Phased Approach

Contract No. 1- Tertiary Treatment (Currently Under Design)

- Phosphorus removal
- Electrical updates

Contract No. 2- Hydraulic Capacity

- Alternative No. 1 Modifications to existing facilities
- Alternative No. 2 New screening facility
- Alternative No. 3 New screening and grit facility

Contract No. 3- Miscellaneous Equipment and System Improvements


- Alternative No. 1 Immediate improvement needs
- Alternative No. 2 Process improvement and rehabilitation needs
- Alternative No. 3 Nitrogen Removal Process Improvement and Rehabilitation Needs

Contract No. 4- Solids Handling Improvements

Dewatering system



WWTP - Site Plan





Recommendation Summary



Needs Area

- Onsite septic systems
- Septage Management Plan



Collection System and I/I Control

- Permit and EPA Order related needs
- Age related needs
- Condition related needs



Groundwater Discharge

- Esten School for additional disposal is an option
- Partnership with Union Point developers to address flow shedding from northern collection system



- Permit and EPA Order related needs
- Age related needs
- Condition related needs
- Design Build Approach



Implementation Plan - Years 1-10

	Total Est.	Plan Year									
Item	Costs Per			3		5	6		8	9	10
	Item	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
Collection System	\$6,741,000	\$150,000	\$155,000	\$160,000	\$200,000	\$1,500,000	\$170,000	\$175,000	\$180,000	\$220,000	\$1,500,000
Pump Stations											
Forest Street	\$964,000					\$964,000					
Lincoln Road	\$618,000					\$618,000					
Wheeler Avenue	\$1,163,000				\$1,163,000						
Summer Street	\$1,170,000				\$1,170,000						
John Burke Drive	\$1,163,000				\$1,163,000						
Hingham Street - North	\$1,628,000						\$1,628,000				
Hingham Street - South	\$1,784,000						\$1,784,000				
Market Street	\$864,000			\$864,000							
Woodsbury Road	\$786,000			\$786,000							
Millbrook Drive	\$765,000					\$765,000					
Old Country Way	\$765,000		\$765,000								
Spruce Street	\$615,000										
Butternut Lane	\$618,000										
WWTP	\$72,000,000	\$1,000,000	\$1,115,000	\$15,512,000	\$641,000	\$640,000	\$9,395,000	\$1,661,000	\$1,661,000	\$24,360,000	\$961,000
Total	\$91,644,000	\$1,150,000	\$2,035,000	\$17,322,000	\$4,337,000	\$4,487,000	\$12,977,000	\$1,836,000	\$1,841,000	\$24,580,000	\$2,461,000



Implementation Plan - Years 11-20

•	Plan Year									
Item	11	12	13	14	15	16	17	18	19	20
	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043
Collection System	\$191,000	\$197,000	\$203,000	\$240,000	\$1,500,000	\$250,000	\$250,000	\$250,000	\$250,000	\$2,000,000
Pump Stations										
Forest Street										
Lincoln Road										
Wheeler Avenue										
Summer Street										
John Burke Drive										
Hingham Street - North										
Hingham Street - South										
Market Street										
Woodsbury Road										
Millbrook Drive										
Old Country Way										
Spruce Street										\$615,000
Butternut Lane										\$618,000
WWTP	\$961,000	\$14,093,000								
Total	\$1,152,000	\$14,290,000	\$203,000	\$240,000	\$1,500,000	\$250,000	\$250,000	\$250,000	\$250,000	\$3,233,000



Funding/Financing

Develop Funding/Financing Plan to Support

- WWTP Upgrade
- Collection system SSES and rehabilitation work

Potential Grant/Loan Funding Opportunities

- 0% SRF Loan for the WWTF Nutrient Upgrades?
- ~2% SRF loan for collection system rehabilitation
- Investigate other grant options
 - Congressional Earmarks
 - MVP & MassWorks

Sewer User Fees

 Rate study findings – Approximately \$75 annual increase each year over next 5 years for average home



Additional Questions?

Additional Questions can be directed to Adam Higgins with Wright-Pierce via email. Questions are due by 5 PM on September 22

adam.higgins@wright-pierce.com



THANK YOU

