

Town of Rockland Public Advisory Notification

The purpose of this email is to notify you of a Sanitary Sewer Overflow as required by 314 CMR 16.00.

On January 10, 2023 at 11:00AM, there was a sanitary sewer discharge or overflow at the Rockland Wastewater Treatment Plant. The discharge or overflow consists of partially treated sewage. This was the result of heavy rains (4.24") from 11/7 - 11/10 and a high groundwater table. The current flow at the treatment plant is currently at an estimated flow of 10.0 Million Gallons per day and the facility is only designed for 2.5 Million Gallons per day.

This discharge could last for days based on the amount of flow currently coming into the facility.

The estimated volume of the discharge/overflow is not known at this time. This Public Advisory Notification will be updated every eight hours or as time allows.

The affected water bodies and land areas affected and/or potentially affected by the discharge or overflow include the following:

- French's Stream

Avoid contact with this water body for 48 hours after the discharge or overflow ceases due to increased health risks from bacteria and other pollutants. See the website below for more information on whether specific resource areas, such as bathing beaches, are affected.

For additional information on discharges and overflows, and the SSO abatement program(s), see Rockland's Sewer Department webpage: <https://rockland-ma.gov/242/Sewer>

Sincerely,

A handwritten signature in blue ink, appearing to read "Charles Heshion".

Charles Heshion - Chairman

Rockland Sewer Commission