Monthly Operating Report

OCTOBER 2023



Rockland, MA WWTP





Mr. Chuck Heshion
Rockland Sewer Commission Chairman
587 Rear Summer Street
Rockland, MA 02370
RE: Rockland Wastewater Facility
Monthly Report—October 2023
Dear Mr. Heshion,
I have enclosed October's 2023 Monthly Operating Report (MOR) for the Veolia Operations and Maintenance contract.
Please contact me if you should you have any questions regarding this report.
Sincerely,
Rick Kotouch
Veolia Project Manager
CC: Daniel Duross
Sherri Vallie

OCTOBER 2023 MONTHLY OPERATING REPORT

1. SUMMARY:

The facility will be reporting **0** exceedance for the month of October 2023

- 1) There was **0** lost time / first aid injuries throughout the month.
- 2) The facility treated a total of 67,004,000 million gallons. The average daily flow was 2.161 MGD
- 3) The total rainfall for this reporting period was 3.36"
- 4) I&I Work is ongoing
- 5) **164** work orders were closed in October, with **17** as corrective maintenance work order and **5** were emergency call outs
- 6) Massachusetts general wastewater permit began April 1st.


2. STAFFING:


Current Employee Licenses as of 09/14/2023										
		Hoi	sting	Wastewater			NEW	NEWEA Laboratory		
Employee	Title	1C Forklift	1B Boom Truck & Forklift	3M	5C	7C	I	II	IV	I
Richard Kotouch	Project Manager					х			Х	
Megan Kelly-Lynch	Asst. Project Manager	Х				Х				
Steven Butts	Lab Technician					Х				Х
Charles Amaral	Maintenance Foreman				Х			Х		
Garry Murrill	Operator				Х			Χ		
Maxwell Jackson	Operator			Х						
Cristian Ryan	Operator									
Michael Hurley	Operator									
Shaun Chaponis (Part Time Weekends)	Operator				Х		Х			

3 FLOWS AND LOADINGS:

3.0 FLOWS, PRECIPITATION, AND WEATHER

- The facility treated a total of 67,004,000 MG during the month. The daily average flow was 2.161 MGD. This was 0.320 MGD less than the previous October monthly average, which was recorded at 2.481 MGD. The highest daily flow was recorded on October 1st as 2.955 MGD. The lowest daily flow was recorded on October 31st as 1.721 MGD.
- The highest *peak* flow was recorded on September 26th as **4.820** MGD.
- A total of 3.36" of precipitation was received at the facility. The highest single day precipitation total was recorded on October 22nd as .90".
- The coldest day was October 31st at 31°F. The warmest day was October 4th at 83°F.






ROCKLAND FLOW AND LOADINGS TRACKING Influent **Effluent | Influent Flow | Effluent Flow** Month/Yr **Flow Flow** Moving Avg. Moving Avg. **MGD MGD MGD** MGD Nov'22 2.295 2.469 Dec'22 3.412 2.544 Jan '23 4.266 2.670 Feb '23 2.942 2.646 2.577 2.646 Mar '23 3.123 3.601 3.601 2.592 Apr '23 2.586 2.212 2.577 2.82 May '23 2.603 2.497 2.174 2.658 **June '23** 2.083 1.735 2.610 2.473 July '23 2.404 2.073 2.666 2.407 Aug '23 2.102 2.024 2.706 2.352 2.374 Sep '23 2.457 2.532 2.76 Oct '23 2.114 2.161 2.351 2.730

3.2 LIFT STATION FLOWS

The lift stations accounted for **9,006,656** gallons throughout the month, **13%** of the total plant flow. Please note that monthly lift station flow totals are purely estimates based off of pump run hours and estimated flow rates. Values are not intended to in any way be used as design capacity volumes for potential future rehab / replacement projects.


Tota	Flows for October 2023										
Total											
Station	Gallons										
Millbrook	1,028,158										
Summer	24,240										
Market	399,000										
John Burke	51,600										
Lincoln, Forest	1,423,800										
Wheeler	21,960										
Woodsbury	1,605,604										
OCW, HN, HS	4,395,595										
Butternut	56,700										
Total:	9,006,656										



	Lift Station Monthly Average Daily Flows (GPD)											
Month	Millbrook	Summer	Market	John Burke	Lincoln	Forrest	Wheeler	Woodsbury	Old Country Way	Hingham North	Hingham South	Butternut
	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD
Nov '22	35,316	1,112	14,450	1,840	2,460	46,410	918	40,740	46,970	142,920	165,599	2640
Dec '22	47,052	888	14,750	2,480	2,580	56,070	786	57,780	60,155	169,200	199,974	3658
Jan '23	47,052	888	14,750	2,480	2,580	56,070	786	57,780	60,155	169,200	199,974	3658
Feb '23	44,087	866	13,554	5,186	3,000	52,950	4,899	50,207	58,650	164,565	199,029	3,182
Mar '23	48,137	1,029	14,893	3,180	3,879	56,625	868	52,650	69,450	172,221	220,629	4,243
Apr '23	46,209	994	15,054	3,180	3,343	57,150	861	52,714	53,325	137,507	170,486	3,857
May '23	36,566	874	15,321	4,226	2,786	49,800	784	40,436	52,425	145,800	180,514	2,796
June '23	32,516	831	12,964	2,983	2,250	50,100	746	34,393	49,575	33,264	178,200	2,411
July '23	32,554	960	13,339	2,897	2,721	54,300	778	44,550	54,300	151,971	174,343	2,475
Aug '23	43,894	857	13,875	3,180	3,086	57,600	5,001	58,243	67,200	180,707	219,858	4,146
Sep '23	30,356	857	13,554	1,637	2,679	51,300	765	45,321	52,650	153,900	166,628	2,379
Oct '23	36,720	866	14,250	1,843	2,550	50,850	784	57,343	50,325	145,414	156,986	2,025
Average	40,038	919	14,230	2,926	2,826	53,269	1,498	49,346	56,265	147,222	186,018	3,123

4.0 SOLIDS HANDLING

The BFP operated a total of **127** hours this month and a total of **428,509** gallons were processed producing **70.46** Wet Tons of sludge that was hauled from the facility. The average BFP feed percent solids were **2.00%** and the BFP Cake average percent solids were **22.64%**. The sludge processing Dry Tons conversion sheet is attached to this report.



Date	BFP Run Hours	Total Digester Feed	Total BFP Feed	Polymer Used	Actual Sludge Weight	Average Press Feed Total Solids	Average Cake Total Solids	Sludge Pick Up	Grit Removed
	HRS	Gal.	Gal.	Gal.	Wet Tons	%	%	Dumpster	Tons
Nov '22	130.0	325,410	393,155	90.4	89.6	1.96	22.45	5.00	
Dec '22	150.5	403,272	472,903	115.2	121.6	1.73	20.27	6.00	
Jan '23	129.2	324,034	377,362	119.2	89.4	1.72	19.24	6.00	
Feb '23	134.3	320,572	355,441	115.5	96.1	1.59	18.77	6.00	
Mar '23	147.1	293,999	445,395	128.8	117.1	1.62	18.98	6.00	
Apr '23	123.3	318,169	377,424	105.6	87.5	2.21	20.87	6.00	
May '23	125.6	329,820	407,350	114.4	123.5	2.08	21.52	6.00	
June '23	183.7	411,781	649,427	155.6	127.6	1.88	22.32	8.00	
July '23	128.4	444,319	510,385	109.6	143.6	2.11	21.39	7.00	
Aug '23	161.6	459,960	577,299	128.1	126.3	2.01	22.81	7.00	
Sep '23	142.7	400,268	473,224	113.6	116.4	1.92	22.35	6.00	
Oct '23	127.4	438,575	428,509	112.0	70.5	2.00	22.64	5.00	
Annual Total	1,683	4,470,179	5,467,874	1,408	1,309	****	****	74	0.00
Avg.	140	372,515	455,656	117	109	1.90	21.13	6.2	****

5.0 ENVIRONMENTAL COMPLIANCE

5.1 REGULATORY REPORTING

1. The EPA and MADEP October NETDMR was submitted on the CDX website on 11/7/2023

5.2 NPDES COMPLIANCE

The facility will be reporting (0) exceedance(s) for the month of October 2023


Date	Plant Flow	BOD	BOD	TSS	TSS	NH3	Total P	Ph	E. Coli Coliform	Aluminum	Copper	Dissolved Oxygen	Limits	Monthly Avg.	Weekly Avg.	Daily Max
	MGD	Mg/L	Lbs./Day	Mg/L	Lbs./Day	Mg/L	Mg/L	Ph	CFU/100 ml	Ug/L	Ug/L	Mg/L	BOD			
Sun, Oct 1	2.955							7.55					Oct. 1 -	20 Mg/L	20 Mg/L	30 Mg/l
Mon, Oct 2	2.720							7.02					Aprill 30	417 bs/day	417 lbs/Day	626 lbs/Day
Tue, Oct 3	2.606							7.46	47				May1 -	6 Mg/L	6 Mg/L	10Mg/L
Wed, Oct 4	2.522	2.0	42	2.0	42	0.10	0.07	7.57		3	3.0		Sept. 30	125 Lbs/Day	125 lbs/Day	209 Lbs/day
Thu, Oct 5	2.454							7.58					TSS			
Fri, Oct 6	2.286							7.55					Oct. 1 -	20 Mg/L	20 Mg/L	30 Mg/l
Sat, Oct 7	2.420							7.50					Aprill 30	417 Lbs/Day	417 Lbs/Dav	626 lbs/Day
Sun, Oct 8	2.360							7.51					May1 -	10 Mg/L	10 Mg/L	15Mg/L
Mon, Oct 9	2.454							7.58	86				Sept. 30	209 Lbs/Day	209 lbs/Day	313 Lhs/day
Tue, Oct 10	2.330							7.55					NH3	LUSTIN		HISTORY
Wed, Oct 11	2.233	5.0	93	3.0	56	0.10	0.16	7.49					Oct.1 - Mar.			
Thu, Oct 12	2.093							7.49					31	3.3 Mg/L	3.3 Mg/l	5.7 Mg/L
Fri, Oct 13	2.018							7.45					Apr. 1 -			
Sat, Oct 14	2.154							7.41					May 31	2.5 Mg/L	2.5 Mg/l	5.7 Mg/l
Sun, Oct 15	2.313							7.47					June1 -			
Mon, Oct 16	2.099							7.47					Sept. 30	1.0 Mg/L	1.0 Mg/L	1.5 Mg/L
Tue, Oct 17	1.720							7.55	108				Total Phps	phorus		
Wed, Oct 18	1.921	4.0	64	4.0	64	0.10	0.14	7.48					Apr.1 -		*******	*******
Thu, Oct 19	1.920							7.35					Oct.31	0.2 Mg/L	**********	**********
Fri, Oct 20	1.900							7.50					Nov. 1 -		******	*******
Sat, Oct 21	2.130							7.33					Mar. 31	1.0 Mg/L	**********	**********
Sun, Oct 22	2.230							7.36					Ph			
Mon, Oct 23	2.090							7.49						6.5	- 8.3	
Tue, Oct 24	2.070							7.53	101				E. Coli			
Wed, Oct 25	2.040	9.0	153	10.0	170	0.10	0.21	7.46						126		409
Thu, Oct 26	1.654							7.44					*******	CFU/100ml	*******	CFU/100ml
Fri, Oct 27	1.813							7.39					Aluminum			
Sat, Oct 28	1.888							6.96					*******	88 ug/l	******	******
Sun, Oct 29	2.131							7.43					Copper			
Mon, Oct 30	2.059							7.61								
Tue, Oct 31	1.421							7.59	16							
Daily Max	2.955	9.00	153.12	10.00	170.14	0.10	0.21	7.61	108.00	******	******	******	May 1 -		> 7.4 mg/L	
Daily Min.	1.421	******	******	******	******	******	*******	6.96	******	******	******		Sept. 30	Plant		
Month Avg.	2.161	5.00	88.00	4.75	83.00	0.10	0.15	7.46	59	3	3.0	******			MGD	
	2.101	5.00	00.00	1.73	03.00	0.10	0.13	7.10	37	J	3.0					

6.0 ENERGY CONSUMPTION


6.1 ELECTRICAL OVERVIEW

The department used a total of **115,631** *KWH* for the month of October 2023. Of this total, the lift stations accounted for **8.9%**, using **10,331** KWH. The Main Plant accounted for the remaining **105,300** KWH. The KWH/ MG treated was **1,386** for the month and the KWH/Lb. BOD Removed was **0.78** KWH/Lb. for the month.

	Monthly Energy Consumption										
Month	Plant Average Daily Flow (NO HFMP)	Plant Total Influent Flow	Plant KWH (Total Billed)	KWH/MG Treated (Plant)	Plant Lbs BOD Removed	KWH/Lb BOD Removed (Plant)	Off Peak Demand (Plant)	Peak Demand (Plant)	Total Lift Station KWH	Total KWH (Plant & Stations)	
	MGD	MG	KWH	KWH/MG	Lbs	KWH/Lb	KW	KW	KWH	KWH	
Oct '22	2.48	76.91	104,700	1,361	101,712	1.03	195	201	14,276	118,976	
Nov '22	2.30	68.86	124,800	1,812	146,152	0.85	186	213	15,469	140,269	
Dec '22	3.36	104.19	146,400	1,405	127,264	1.15	243	258	19,421	165,821	
Jan '23	4.08	126.55	134,400	1,062	126,998	1.06	252	258	20,049	154,449	
Feb '23	2.94	82.38	125,400	1,522	92,522	1.36	213	210	16,712	142,112	
Mar '23	3.33	103.31	129,600	1,254	103,530	1.25	204	213	16,322	145,922	
Apr '23	2.59	77.57	116,400	1,501	130,686	0.89	198	210	15,893	132,293	
May '23	2.5	77.4	118,800	1,535	151,100	0.79	183	189	12,637	131,437	
Jun '23	1.73	52.04	118,200	2,271	149,709	0.79	183	201	12,127	130,327	
Jul '23	2.07	64.26	108,300	1,685	137,511	0.79	222	231	10,113	118,413	
Aug '23	2.02	62.74	120,600	1,922	142,457	0.85	192	201	10,893	131,493	
Sep '23	2.53	75.95	105,300	1,386	134,488	0.78	195	213	10,331	115,631	
Average	2.66	81.01	121,075	1,560	128,677	0.97	206	217	14,520	135,595	



	Monthly Lift Station KWH													
Month	Hingham North	Hingham South	Spruce	Butternut	Old Country Way	Market	Woodsbury	Lincoln	Forest	Wheeler	Summer	Milbrook	John Burke	Total
Oct '22	2,943	4,100	195	73	952	887	1,308	260	1,942	69	80	1,325	142	14,276
Nov'22	2,907	4,600	218	66	1,184	832	1,240	308	2,043	63	67	1,734	207	15,469
Dec'22	3,575	6,100	156	83	1,427	957	1,841	352	2,515	63	63	2,026	263	19,421
Jan '23	3,577	6,500	145	90	1,802	924	1,848	341	2,466	123	62	1,863	308	20,049
Feb '23	3,039	5,000	141	70	1,281	862	1,440	325	2,187	227	59	1,749	332	16,712
Mar '23	2,995	5,100	246	434	1,260	851	1,353	283	1,915	58	67	1,524	236	16,322
Apr '23	3,531	4,100	176	0	1,174	781	1,447	311	2,179	82	65	1,922	125	15,893
May '23	2,373	3,800	114	69	956	695	1,034	201	1,587	57	59	1,459	233	12,637
Jun '23	2,040	4,200	145	62	887	409	1,116	186	1,714	65	63	1,064	176	12,127
Jul '23	1,810	3,600	157	57	897	306	868	156	1,159	56	58	891	98	10,113
Aug '23	2,145	3,400	109	58	911	313	838	163	1,933	59	56	818	90	10,893
Sep '23	1,646	3,400	226	53	911	403	967	188	1,478	56	52	874	77	10,331
Average	2,715	4,492	169	93	1,137	685	1,275	256	1,927	82	63	1,437	191	14,520



7.0 MAINTENANCE

7.1 WORK ORDER OVERVIEW

WO Type	Total This Month	Total This Year
Preventative Maintenance	164	691
Corrective Maintenance	17	64
Emergency Call Outs Total	5	13

7.2 EMERGENCY CALL OUTS FOR THE MONTH

Туре	Total this Month	Total this Year
Sewer Back Up / Collection System	0	2
Pump Station	4	9
Plant	0	0
Odor	0	0
Power Outages	1	1
Total:	5	15

7.3 INSPECTIONS / ANNUAL PMS COMPLETED DURING THE MONTH

- 1. All pump station alarms checked
- 2. Spruce probe cleaned weekly
- 3. Eye wash inspections completed weekly
- 4. Fire extinguisher inspections completed monthly
- 5. Dependable Petroleum monthly UST Inspection
- 6. Appollo Safety Quarterly Inspection replaced methane sensor
- 7. Applied Dynamics Annual Chain fall inspection


7.4 COLLECTION SYSTEM AND IPP ASSISTANCE PERFORMED BY VEOLIA

COLLECTION SYSTEM ASSITANCE:

Туре	Total This Month	Total This Year
Sewer Inspection / Tie-Ins	0	0
Sewer Location mark Outs	49	299
Sewer Back Up	1	1

7.5 WORK ORDER STATISTICS

There were 156.57 total reported maintenance hours during the month. Of this total, outside contractors accounted for 53% with **83** hours recorded.



8.0 FINANCIAL ACCOUNTING- REPAIR / MAINTENANCE (JULY '23 - JUNE '24)

ltem	Budget	Spent Month	Spent Year	Remaining
R & M (Project)	\$100,000.00	\$7,961.07	\$36,674.63	\$63,325.37

8.1 SIGNIFICANT R&M PURCHASES

- 1. Seacoast Supply removed Digester Recirculation Pump #1 \$2,363.05
- 2. John Hoadley & Sons jetted lime room floor drain \$1,600.00
- 3. Ordered a BFP Polymer Pump from Grainger \$1,177.61

9.0 ATTACHED REPORTS

- Discharge Monitoring Report
- HACH Wims Data Reports
- Cumulative and Monthly Violation Reports
- Financial Reports
- Solids Removal Summary