
Monthly Operating Report

DECEMBER 2023



Rockland, MA WWTP







Mr. Chuck Heshion
Rockland Sewer Commission Chairman
587 Rear Summer Street
Rockland, MA 02370
RE: Rockland Wastewater Facility
Monthly Report—December 2023
Dear Mr. Heshion,
I have enclosed December's 2023 Monthly Operating Report (MOR) for the Veolia Operations and Maintenance contract.
Please contact me if you should you have any questions regarding this report.
Sincerely,
Diali Katawah
Rick Kotouch
Veolia Project Manager
CC:
Daniel Duross Sherri Vallie
5.15.1.1 · 5.11.0

DECEMBER 2023 MONTHLY OPERATING REPORT

1. SUMMARY:

The facility will be reporting **0** exceedance for the month of November 2023

- 1) There was **0** lost time / first aid injuries throughout the month.
- 2) The facility treated a total of 86,494,000 million gallons. The average daily flow was 2.790 MGD
- 3) The total rainfall for this reporting period was **6.57**"
- 4) I&I Work is ongoing
- 5) 179 work orders were closed in December, with 11 as corrective maintenance work order and 7 were emergency call outs
- 6) Massachusetts general wastewater permit began April 1st.


2. STAFFING:


Current Employee Licenses as of 09/14/2023										
		Hoi	sting	Wastewater			NEWEA Collections			NEWEA Laboratory
Employee	Title	1C Forklift	1B Boom Truck & Forklift	3M	5C	7C	I	II	IV	I
Richard Kotouch	Project Manager					Х			X	
Megan Kelly-Lynch	Asst. Project Manager	Х				Х				
Steven Butts	Lab Technician					Х				Х
Charles Amaral	Maintenance Foreman				Х			Х		
Garry Murrill	Operator				Х			Χ		
Maxwell Jackson	Operator			Х						
Cristian Ryan	Operator									
Michael Hurley	Operator									
Shaun Chaponis (Part Time Weekends)	Operator				Х		Х			

3 FLOWS AND LOADINGS:

3.0 FLOWS, PRECIPITATION, AND WEATHER

- The facility treated a total of 86,494,000 MG during the month. The daily average flow was 2.790 MGD. This was 0.571 MGD less than the previous December monthly average, which was recorded at 3.361 MGD. The highest daily flow was recorded on December 12th as 3.940 MGD. The lowest daily flow was recorded on December 3rd as 1.598 MGD.
- The highest peak flow was recorded on December 11th as 6.060 MGD.
- A total of **6.57**" of precipitation was received at the facility. The highest single day precipitation total was recorded on December 17th as **1.85**".
- The coldest day was December 23rd at 15°F. The warmest day was December 18th at 62°F.






ROCKLA	ROCKLAND FLOW AND LOADINGS TRACKING									
Month/Yr	Influent Flow	Effluent Flow	Influent Flow Moving Avg.	Effluent Flow Moving Avg.						
	MGD	MGD	MGD	MGD						
Jan '23	4.266		2.670							
Feb '23	2.942	2.646	2.577	2.646						
Mar '23	3.601	3.601	2.592	3.123						
Apr '23	2.586	2.212	2.577	2.82						
May '23	2.497	2.174	2.603	2.658						
June '23	2.083	1.735	2.61	2.473						
July '23	2.404	2.073	2.666	2.407						
Aug '23	2.102	2.024	2.706	2.352						
Sep '23	2.457	2.532	2.76	2.374						
Oct '23	2.114	2.161	2.73	2.351						
Nov '23	2.069	2.069	2.711	2.323						
Dec '23	3.302	2.79	2.702	2.365						

3.2 LIFT STATION FLOWS

The lift stations accounted for **9,970,926** gallons throughout the month, **12%** of the total plant flow. Please note that monthly lift station flow totals are purely estimates based off of pump run hours and estimated flow rates. Values are not intended to in any way be used as design capacity volumes for potential future rehab / replacement projects.

Total	Flows for December 202	3
	Total	
Station	Gallons	
Millbrook	1,003,319	
Summer	27,120	
Market	403,500	
John Burke	62,640	
Lincoln, Forest	1,659,002	
Wheeler	22,140	
Woodsbury	1,402,205	
OCW, HN, HS	5,292,000	
Butternut	99,000	
Total:	9,970,926	



Lift Station Monthly Average Daily Flows (GPD) Old Country Hingham Hingham Woodsbury Wheeler Millbrook Market John Burke Lincoln Summer Forrest Butternut Way North South Month GPD Jan '23 47,052 888 14,750 2,480 2,580 56,070 786 57,780 60,155 169,200 199,974 3658 Feb '23 866 44,087 13,554 5,186 52,950 4,899 50,207 58,650 164,565 199,029 3182 3,000 Mar '23 48,137 1,029 14,893 3,180 3,879 56,625 868 52,650 69,450 172,221 220,629 4243 Apr '23 46,209 994 15,054 57,150 861 3,857 3,180 3,343 52,714 53,325 137,507 170,486 May 123 36,566 874 15,321 2,786 49,800 784 40,436 2,796 4,226 52,425 145,800 180,514 June '23 32.516 831 12,964 2,983 2,250 50,100 746 34,393 49,575 33,264 178,200 2,411 July '23 13,339 2,897 2,721 54,300 2,475 960 778 44,550 32,554 54,300 151,971 174,343 Aug '23 43,894 857 13,875 57,600 58,243 4,146 3,180 3,086 5,001 67,200 180,707 219,858 Sep '23 30,356 857 13,554 1,637 2,679 51,300 765 45,321 52,650 153,900 166,628 2,379 Oct '23 866 50,850 36,720 14,250 1,843 2,550 784 57,343 50,325 145,414 156,986 2,025 Nov '23 30,047 857 13,286 3,137 2,743 58,050 1,080 36,450 46,650 130,757 2,539 145,414 Dec '23 969 3,536 35,833 14,411 2,237 2,936 59,250 791 50,079 57,300 153,128 189,000

38,664

Average

904

14,104

2,879

3,014

54,504

1,512

48,347

56,000


144,870

183,422

3,104

4.0 SOLIDS HANDLING

The BFP operated a total of **150.45** hours this month and a total of **454,170** gallons were processed producing **97.94** Wet Tons of sludge that was hauled from the facility. The average BFP feed percent solids were **2.04%** and the BFP Cake average percent solids were **21.95%**. The sludge processing Dry Tons conversion sheet is attached to this report.



Date	BFP Run Hours	Total Digester Feed	Total BFP Feed	Polymer Used	Actual Sludge Weight	Average Press Feed Total Solids	Average Cake Total Solids	Sludge Pick Up	Grit Removed
	HRS	Gal.	Gal.	Gal.	Wet Tons	%	%	Dumpster	Tons
Jan '23	129.2	324,034	377,362	119.2	89.4	1.72	19.24	6.00	
Feb '23	134.3	320,572	355,441	115.5	96.1	1.59	18.77	6.00	
Mar '23	147.1	293,999	445,395	128.8	117.1	1.62	18.98	6.00	
Apr '23	123.3	318,169	377,424	105.6	87.5	2.21	20.87	6.00	
May '23	125.6	329,820	407,350	114.4	123.5	2.08	21.52	6.00	
June '23	183.7	411,781	649,427	155.6	127.6	1.88	22.32	8.00	
July '23	128.4	444,319	510,385	109.6	143.6	2.11	21.39	7.00	
Aug '23	161.6	459,960	577,299	128.1	126.3	2.01	22.81	7.00	
Sep '23	142.7	400,268	473,224	113.6	116.4	1.92	22.35	6.00	
Oct '23	127.4	438,575	428,509	112.0	70.5	2.00	22.64	5.00	
Nov '23	132.4	389,377	381,901	108.8	116.0	2.18	22.12	8.00	
Dec '23	150.5	460,829	454,170	137.6	97.9	2.04	21.95	6.00	
Annual Total	1,686	4,591,703	5,437,887	1,449	1,312	****	****	77	0.00
Avg.	140	382,642	453,157	121	109	1.95	21.25	6.4	****

5.0 ENVIRONMENTAL COMPLIANCE

5.1 REGULATORY REPORTING

1. The EPA and MADEP December NETDMR was submitted on the CDX website on 1/8/2024.

5.2 NPDES COMPLIANCE

The facility will be reporting (1) exceedance(s) for the month of December 2023


Date	Plant Flow	BOD	BOD	TSS	TSS	NH3	Total P	Ph	E. Coli Coliform	Aluminum	Copper	Dissolved Oxygen	Limits	Monthly Avg.	Weekly Avg.	Daily Max
	MGD	Mg/L	Lbs./Day	Mg/L	Lbs./Day	Mg/L	Mg/L	Ph	CFU/100 ml	Ug/L	Ug/L	Mg/L	BOD			
Fri, Dec 1	1.616	-						7.62					Oct. 1 -	20 Mg/L	20 Mg/L	30 Mg/l
Sat, Dec 2	1.676							7.59					Aprill 30	417 bs/day	417 lbs/Day	626 lbs/Day
Sun, Dec 3	1.598							7.44					May1 -	6 Mg/L	6 Mg/L	10Mg/L
Mon, Dec 4	2.701							7.47					Sept. 30	125 Lbs/Day	125 lbs/Day	209 Lbs/day
Tue, Dec 5	2.431							7.44	31				TSS			112311712
Wed, Dec 6	2.503	6.0	125	2.0	42	0.30	0.18	7.38		16	4.0		Oct. 1 -	20 Mg/L	20 Mg/L	30 Mg/l
Thu, Dec 7	2.390							7.47					Aprill 30	417 Lbs/Day	417 Lbs/Day	626 lbs/Day
Fri, Dec 8	2.227							7.45					May1 -	10 Mg/L	10 Mg/L	15Mg/L
Sat, Dec 9	2.389							7.49					Sept. 30	209 Lbs/Day	209 lbs/Day	313 Lbs/day
Sun, Dec 10	2.534							7.46					NH3			112311712
Mon, Dec 11	2.864							7.55					Oct.1 - Mar.			
Tue, Dec 12	3.940							7.54	387				31	3.3 Mg/L	3.3 Mg/l	5.7 Mg/L
Wed, Dec 13	3.236	5.0	135	7.0	189			7.44					Apr. 1 -			
Thu, Dec 14	3.000							7.48	41				May 31	2.5 Mg/L	2.5 Mg/l	5.7 Mg/l
Fri, Dec 15	2.777							7.48					June1 -			
Sat, Dec 16	2.623							7.40					Sept. 30	1.0 Mg/L	1.0 Mg/L	1.5 Mg/L
Sun, Dec 17	2.686							7.47					Total Phps	phorus		
Mon, Dec 18	3.135							7.63					Apr.1 -	0011.0	*******	*******
Tue, Dec 19	3.907							7.38					Oct.31	0.2 Mg/L	*********	******
Wed, Dec 20	3.570	10.0	298	5.0	149	0.50	0.19	7.40	28				Nov. 1 -		*******	*******
Thu, Dec 21	3.454							7.38					Mar. 31	1.0 Mg/L	*******	********
Fri, Dec 22	3.018							7.37					Ph			
Sat, Dec 23	2.858							7.25						6.5	- 8.3	
Sun, Dec 24	2.780							7.31					E. Coli			
Mon, Dec 25	2.841							7.44					*****	126	*******	409
Tue, Dec 26	2.782							7.44	378				*********	CFU/100ml	*******	CFU/100ml
Wed, Dec 27	2.919	10.0	243	2.0	49			7.47					Aluminum			
Thu, Dec 28	3.108							7.46					******	88 ug/l	******	******
Fri, Dec 29	3.101							7.45					Copper			
Sat, Dec 30	2.984							7.42								
Sun, Dec 31	2.846							7.37								
Daily Max	3.940	10.00	297.74	7.00	188.92	0.50	0.19	7.63	387.00	******	******	******	May 1 -		> 7.4 mg/L	
Daily Min.	1.598	******	******	******	******	******	******	7.25	******	******	******		Sept. 30	Plan	t Flow	
Month Avg.	2.790	7.75	200.25	4.00	107.25	0.40	0.19	7.45	88	16	4.0	******			MGD	

6.0 ENERGY CONSUMPTION


6.1 ELECTRICAL OVERVIEW

The department used a total of **142,597** *KWH* for the month of December 2023. Of this total, the lift stations accounted for **9.3%**, using **142,597** KWH. The Main Plant accounted for the remaining **129,300** KWH. The KWH/ MG treated was **2,083** for the month and the KWH/Lb. BOD Removed was **2.95** KWH/Lb. for the month.

	Monthly Energy Consumption										
Month	Plant Average Daily Flow (NO HFMP)	Plant Total Influent Flow	Plant KWH (Total Billed)	KWH/MG Treated (Plant)	Plant Lbs BOD Removed	KWH/Lb BOD Removed (Plant)	Off Peak Demand (Plant)	Peak Demand (Plant)	Total Lift Station KWH	Total KWH (Plant & Stations)	
	MGD	MG	KWH	KWH/MG	Lbs	KWH/Lb	KW	KW	KWH	KWH	
Dec '22	3.36	104.19	146,400	1,405	127,264	1.15	243	258	19,421	165,821	
Jan '23	4.08	126.55	134,400	1,062	126,998	1.06	252	258	20,049	154,449	
Feb '23	2.94	82.38	125,400	1,522	92,522	1.36	213	210	16,712	142,112	
Mar '23	3.33	103.31	129,600	1,254	103,530	1.25	204	213	16,322	145,922	
Apr '23	2.59	77.57	116,400	1,501	130,686	0.89	198	210	15,893	132,293	
May '23	2.5	77.4	118,800	1,535	151,100	0.79	183	189	12,637	131,437	
Jun '23	1.73	52.04	118,200	2,271	149,709	0.79	183	201	12,127	130,327	
Jul '23	2.07	64.26	108,300	1,685	137,511	0.79	222	231	12,127	130,327	
Aug '23	2.02	62.74	120,600	1,922	142,457	0.85	192	201	10,113	118,413	
Sep '23	2.53	75.95	105,300	1,386	134,488	0.78	195	213	10,893	131,493	
Oct '23	2.16	67.00	104,700	1,563	134,616	0.78	195	201	10,331	115,631	
Nov'23	2.07	62.06	129,300	2,083	43,777	2.95	207	234	13,297	142,597	
Average	2.62	79.62	121,450	1,599	122,888	1.12	207	218	14,160	136,735	



	Monthly Lift Station KWH													
Month	Hingham North	Hingham South	Spruce	Butternut	Old Country Way	Market	Woodsbury	Lincoln	Forest	Wheeler	Summer	Milbrook	John Burke	Total
Nov'22	2,907	4,600	218	66	1,184	832	1,240	308	2,043	63	67	1,734	207	15,469
Dec'22	3,575	6,100	156	83	1,427	957	1,841	352	2,515	63	63	2,026	263	19,421
Jan '23	3,577	6,500	145	90	1,802	924	1,848	341	2,466	123	62	1,863	308	20,049
Feb '23	3,039	5,000	141	70	1,281	862	1,440	325	2,187	227	59	1,749	332	16,712
Mar'23	2,995	5,100	246	434	1,260	851	1,353	283	1,915	58	67	1,524	236	16,322
Apr '23	3,531	4,100	176	0	1,174	781	1,447	311	2,179	82	65	1,922	125	15,893
May '23	2,373	3,800	114	69	956	695	1,034	201	1,587	57	59	1,459	233	12,637
Jun '23	2,040	4,200	145	62	887	409	1,116	186	1,714	65	63	1,064	176	12,127
Jul '23	1,810	3,600	157	57	897	306	868	156	1,159	56	58	891	98	10,113
Aug '23	2,145	3,400	109	58	911	313	838	163	1,933	59	56	818	90	10,893
Sep '23	1,646	3,400	226	53	911	403	967	188	1,478	56	52	874	77	10,331
Oct '23	2,204	3,700	151	60	1,003	792	1,523	257	1,894	91	61	1,389	172	15,313
Average	2,654	4,458	165	92	1,141	677	1,293	256	1,923	83	61	1,443	193	14,607



7.0 MAINTENANCE

7.1 WORK ORDER OVERVIEW

WO Type	Total This Month	Total This Year
Preventative Maintenance	179	1,040
Corrective Maintenance	11	100
Emergency Call Outs Total	7	27

7.2 EMERGENCY CALL OUTS FOR THE MONTH

Туре	Total this Month	Total this Year
Sewer Back Up / Collection System	0	2
Pump Station	3	17
Plant	2	4
Odor	0	0
Power Outages	2	3
Total:	7	26

7.3 INSPECTIONS / ANNUAL PMS COMPLETED DURING THE MONTH

- 1. All pump station alarms checked
- 2. Spruce probe cleaned weekly
- 3. Eye wash inspections completed weekly
- 4. Fire extinguisher inspections completed monthly
- 5. Dependable Petroleum monthly UST Inspection
- 6. Appollo Safety Quarterly Inspection


7.4 COLLECTION SYSTEM AND IPP ASSISTANCE PERFORMED BY VEOLIA

COLLECTION SYSTEM ASSITANCE:

Туре	Total This Month	Total This Year			
Sewer Inspection / Tie-Ins	1	1			
Sewer Location mark Outs	26	364			
Sewer Back Up	0	1			

7.5 WORK ORDER STATISTICS

There were 118.82 total reported maintenance hours during the month. Of this total, outside contractors accounted for 43% with **51** hours recorded.



8.0 FINANCIAL ACCOUNTING- REPAIR / MAINTENANCE (JULY '23 - JUNE '24)

Item	Budget	Spent Month	Spent Year	Remaining
R & M (Project)	\$100,000.00	\$7,783.16	\$52,563.43	\$47,436.57

8.1 SIGNIFICANT R&M PURCHASES

- 1. Purchased a polymer pump motor from Blanchard Electric \$1,010.00
- 2. Annual support fee for Linko Technology CMMS Program \$1,371.00
- 3. 10' step rolling ladder from Grainger \$1,775.29

9.0 ATTACHED REPORTS

- Discharge Monitoring Report
- HACH Wims Data Reports
- Cumulative and Monthly Violation Reports
- Financial Reports
- Solids Removal Summary