

## Town of Rockland Public Advisory Notification

The purpose of this email is to notify you of a Sanitary Sewer Overflow as required by 314 CMR 16.00.

On March 10, 2024 at 11:00AM, there was a sanitary sewer discharge or overflow at the Rockland Wastewater Treatment Plant. The discharge or overflow consists of partially treated sewage that is blended with our final effluent flow.

As of 3/11/2024 at 8:00am the discharge or overflow of the partially treated sewage has been on-going intermittently for the past **21.0** hours with an estimated volume of **875,000** gallons.

The affected water bodies and land areas affected and/or potentially affected by the discharge or overflow include the following:

- French's Stream

Avoid contact with this water body for 48 hours after the discharge or overflow ceases due to increased health risks from bacteria and other pollutants. See the website below for more information on whether specific resource areas, such as bathing beaches, are affected.

For additional information on discharges and overflows, and the SSO abatement program(s), see Rockland's Sewer Department webpage: <https://rockland-ma.gov/242/Sewer>

Sincerely,

*Charles Heshion*

Charles Heshion - Chairman

Rockland Sewer Commission