

Monthly Operating Report

JULY 2024



Rockland, MA WWTP



Sherri Vallie



Mr. Chuck Heshion
Rockland Sewer Commission Chairman
587 Rear Summer Street
Rockland, MA 02370
RE: Rockland Wastewater Facility
Monthly Report—July 2024
Dear Mr. Heshion,
I have enclosed July's 2024 Monthly Operating Report (MOR) for the Veolia Operations and Maintenance contract.
Please contact me if you should you have any questions regarding this report.
Sincerely,
Megan Lynch
Veolia Project Manager
CC: Daniel Duross

JULY 2024 Monthly Operating Report

1. SUMMARY:

The facility will be reporting 0 exceedance for the month of July 2024

- 1) There was **0** lost time / first aid injuries throughout the month.
- 2) The facility treated a total of 45.279 million gallons. The average daily flow was 1.461 MGD
- 3) The total rainfall for this reporting period was 4.52"
- 4) I&I Work is ongoing
- 5) **195** work orders were closed out, with **28** as corrective maintenance work orders and **4** were emergency call outs.


2. Staffing:


			Current En	ıployee L	icenses :	as of 07/	8/2024				
		Hoisting		Wastewater				NEWEA Collections			NEWEA Laboratory
Employee	Title	1C Forklift	1B Boom Truck & Forklift	3M	3M 5C 6C 7C		I	II	IV	I	
Megan Lynch	Project Manager						Х				
Jesse Freeman	Asst. Project Manager					Х					
Steven Butts	Lab Technician						Х				Х
Charles Amaral	Maintenance Foreman				Х				Х		
Garry Murrill	Operator				Х				Х		
Cristian Ryan	Operator			Х							
Yuri Fernandes	Operator				Х						
Fred Anzivino	Operator										
Sha un Chaponis (Part Time Weekends)	Operator				Х			Х			

3. FLows and Loadings:

3.0 FLOWS, PRECIPITATION, AND WEATHER

- The facility treated a total of 45,279 MG during the month. The daily average flow was 1.461 MGD. This was 0.563 MGD less than the previous July monthly average, which was recorded at 2.024 MGD. The highest daily flow was recorded on July 7th as 1.702 MGD. The lowest daily flow was recorded on July 29th as 1.178 MGD.
- The highest *peak* flow was recorded on July 6th as **3.890** MGD.
- A total of 4.52" of precipitation was received at the facility. The highest single day precipitation total was recorded on July 6th as 0.90".
- The coldest day was July 3rd 6th at 55°F. The warmest day was March 31st at 92°F.






ROCKLAND FLOW AND LOADINGS TRACKING Influent Effluent Influent Flow Effluent Flow Month/Yr Flow Moving Avg. Flow Moving Avg. **MGD MGD** MGD **MGD** Aug '23 2.102 2.024 2.706 2.352 Sep '23 2.457 2.532 2.760 2.374 Oct '23 2.114 2.161 2.730 2.351 Nov '23 2.069 2.069 2.711 2.323 Dec '23 3.302 2.790 2.702 2.365 Jan '24 4.110 3.477 2.689 2.458 Feb '24 2.884 2.905 2.684 2.479 Mar '24 4.212 3.836 2.735 2.499 3.886 3.534 2.843 2.609 Apr '24 May '24 2.899 2.614 2.877 2.646 Jun '24 2.317 2.034 2.896 2.671 Jul '24 1.723 1.461 2.839 2.620

3.2 LIFT STATION FLOWS

The lift stations accounted for **7,852,400** gallons throughout the month, **17%** of the total plant flow. Please note that monthly lift station flow totals are purely estimates based off of pump run hours and estimated flow rates. Values are not intended to in any way be used as design capacity volumes for potential future rehab / replacement projects.

То	tal Flows for July 2024	
Station	Total Gallons	
	830,520	
Millbrook	·	
Summer	26,160	
Market	417,000	
John Burke	58,560	
Lincoln, Forest	1,346,100	
Wheeler	86,220	
Woodsbury	1,087,200	
OCW, HN, HS	4,698,000	
Butternut	79,200	
Spruce	54,000	
Total:	7,852,440	



Month	Millbrook	Summer	Market	John Burke	Lincoln	Forrest	Wheeler	Woodsbury	Old Country Way	Hingham North	Hingham South	Butternut	Spru
	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD	GPD
Aug'23	43,894	857	13,875	3,180	3,086	57,600	5,001	58,243	67,200	180,707	219,858	4,146	
Sep '23	30,356	857	13,554	1,637	2,679	51,300	765	45,321	52,650	153,900	166,628	2,379	
Oct '23	36,720	866	14,250	1,843	2,550	50,850	784	57,343	50,325	145,414	156,986	2,025	
Nov '23	30,047	857	13,286	3,137	2,743	58,050	1,080	36,450	46,650	130,757	145,414	2,539	
Dec '23	35,833	969	14,411	2,237	2,936	59,250	791	50,079	57,300	153,128	189,000	3,536	
Jan'24	36,373	1,123	18,643	2,246	3,836	62,700	849	66,793	82,050	174,729	242,614	5,271	
Feb'24	32,207	909	14,946	2,949	3,536	51,000	797	47,700	56,475	148,693	177,043	4,243	
Mar'24	43,470	1,320	14,411	3,317	7,500	58,200	1,061	61,714	77,625	193,436	246,471	5,529	
Apr'24	31,912	1,099	15,290	3,066	2,787	52,568	842	58,355	78,852	184,994	236,903	5,632	
May'24	33,062	952	14,419	2,245	2,768	53,042	854	47,787	53,381	159,735	204,503	3,339	3,62
June'24	27,941	883	12,968	2,036	2,516	47,894	830	40,877	47,352	137,334	173,148	2,700	2,46
July'24	26,791	844	13,452	1,889	2,439	43,423	2,781	35,071	35,429	133,084	151,548	2,555	1,74

4.0 SOLIDS HANDLING

The BFP operated a total of **183.45** hours this month and a total of **587,962** gallons were processed producing **130.6** Wet Tons of sludge that was hauled from the facility. The average BFP feed percent solids were **2.32%** and the BFP Cake average percent solids were **21.64%**. The sludge processing Dry Tons conversion sheet is attached to this report.

Date	BFP Run Hours	Total Digester Feed	Total BFP Feed	Polymer Used	Actual Sludge Weight	Average Press Feed Total Solids	Average Cake Total Solids	Sludge Pick Up	Grit Removed
	HRS	Gal.	Gal.	Gal.	Wet Tons	%	%	Dumpster	Tons
Aug '23	161.6	459,960	577,299	128.1	126.3	2.01	22.81	7.00	
Sep '23	142.7	400,268	473,224	113.6	116.4	1.92	22.35	6.00	
Oct '23	127.4	438,575	428,509	112.0	70.5	2.00	22.64	5.00	
Nov '23	132.4	389,377	381,901	108.8	116.0	2.18	22.12	8.00	
Dec '23	150.5	460,829	454,170	137.6	97.9	2.04	21.95	6.00	
Jan '24	152.4	436,721	432,214	123.2	135.3	2.27	20.80	7.00	
Feb '24	130.5	311,234	362,674	111.2	100.1	2.05	22.41	6.00	
Mar '24	122.3	331,384	362,712	119.2	85.7	2.32	21.64	6.00	
Apr '24	164.0	321,384	500,524	131.2	50.9	1.69	21.51	6.00	
May '24	131.0	371,436	373008	108.0	66.4	1.81	20.97	5.00	5.00
Jun '24	114.9	438,919	357,639	99.4	49.3	1.80	21.50	5.00	
Jul '24	114.9	620,475	587,962	157.5	130.6	2.06	21.84	8.00	
Annual Total	1,644	4,980,562	4,918,828	1,450	1,145	****	****	75	5.00
Avg.	137	415,047	447,166	121	95	2.01	21.88	6.3	****

5.0 Environmental compliance

5.1 REGULATORY REPORTING

1. The EPA and MADEP July NETDMR was submitted on the CDX website on 7/14/2024.

5.2 NPDES COMPLIANCE

The facility will be reporting (0) exceedance(s) for the month of July 2024

Date	Plant Flow	BOD	BOD	TSS	TSS	NH3	Total P	Ph	E. Coli Coli form	Aluminum	Copper	Dissolved Oxygen	Limits	Monthly Avg.	Weekly Avg.	Daily Max
	MGD	Mg/L	Lbs./Day	Mg/L	Lbs./Day	Mg/L	Mg/L	Ph	CFU/100 ml	Ug/L	Ug/L	Mg/L	BOD			
Mon,Jul1	1628							7.48				87	Oct. 1 -	20 Mg/L	20 Mg/L	3D Mg/I
Tue, Jul 2	1656							7.40	22			90	April 3D	417 bs/day	417 bs/Day	626 lbs/Day
Wed, Jul3	1522	20	25	3.0	38	070	002	7.40		8	40	91	May1 -	6 Mg/L	6 Mg/L	1DMg/L
Thu,Jul4	1519							7.37				91	Sept 3D	125 Lhs/Dav	1 25 bs/Day	209 Lhs/dav
Fri, Jul 5	1556							7.37				87	122			
Sat, Jul 6	1616							7.39				86	Oct. 1 -	20 Mg/L	20 Mg/L	3D Mg/I
Sun, Jul 7	1702							7.40				87	April 3D	417 Lhs/Daz	417 Lhs/Dav	626 lbs/Day
Mon, Jul8	1488							7.52				84	May1 -	10 Mg/L	10 Mg/L	15Mg/L
Tue, Jul 9	1503							7.48	4			81	Sept 3D	209 Lhs/Dav	209 bs/Day	313 Lhs/dav
Wed,Jul10	1.488	60	74	20	25		001	7.50				83	NH3	1115/11/60		1115/1176
Thu,Jul11	1569							7.48				86	Oct.1 - Mar.			5714.0
Fri, Jul 12	1506							7.64				85	31	3.3 Mg/L	3.3 Mg/I	5.7 Mg/L
Sat, Jul 13	1534							7.44				81	Apr. 1 -	0.514-0	0.514-0	F.7.14-0
Sun, Jul 14	1472							7.35				83	May 31	2.5 Mg/L	2.5 Mg/I	5.7 Mg/I
Mon,Jul15	1,555							7.64				84	Junet -			
Tue, Jul 16	1.452							7.58	46			80	Sept 3D	1.D Mg/L	1.D Mg/L	1.5 Mg/L
Wed,Jul17	1332	3.0	33	80	89	020	009	7.45				85	Total Phps	phorus		
Thu,Jul18	1489							7.52				81	Apr.1 -		******	******
Fri, Jul 19	1506							7.46				86	Oct 31	D.2 Mg/L	*******	********
Sat, Jul 20	1.395							7.25				86	Nov. 1 -		******	
Sun, Jul 21	1424							7.39				87	Mar. 31	1.D Mg/L	*******	*******
Mon, Jul 22	1355							7.29				81	Ph			
Tue, Jul 23	1395							7.31	20			85		6.5	- 8.3	
Wed, Jul 24	1400	40	47	20	23		010	7.20				87	E. Coli			
Thu, Jul 25	1383							7.21				80		126		409
Fri, Jul 26	1.331							7.39				86	******	CFU/100ml	******	CFU/I DDml
Sat, Jul 27	1228							7.46				96	Aluminum			
Sun, Jul 28	1.363							7.40				83	*****	88 ug/l	******	*****
Mon, Jul 29	1178							7.36				86	Copp er			
Tue, Jul 30	1392							7.38	20			84				
Wed, Jul 31	1342	3.D	34	3.0	34		013	7.26				80				
						0.000			46.00	***********	**********	********	May 1 -		> 7.4 mg/L	
Daily Max	1702	600 ******	74.46	800	88.87 ***********	0.70 ******	013	7.64	46.00 *******	**********	*************		Sent 3D	- Diam	> r.4 myc	
Daily Min.	1.178							7.20				800				
Month Avg.	1461	360	42.60	3.60	41.80	045	0.07	7.41	17	8	40	**************************************		2.5	MGD	

6.0 Energy ConsumptioN

6.1 ELECTRICAL OVERVIEW

The department used a total of **133,930** *KWH* for the month of July 2024. Of this total, the lift stations accounted for **15.1%**, using **10,930** KWH. The Main Plant accounted for the remaining **123,000** KWH. The KWH/ MG treated was **2,716** for the month and the KWH/Lb. BOD Removed was **0.90** KWH/Lb. for the month.

7.0 Mai	INTENANCE									
Month	Plant Average Daily Flow (NO HFMP)	Plant Total Influent Flow	Plant KWH (Total Billed)	KWH/MG Treated (Plant)	Plant Lbs BOD Removed	KWH/Lb BOD Removed (Plant)	Off Peak Demand (Plant)	Peak Demand (Plant)	Total Lift Station KWH	Total KWH (Plant & Stations)
	MGD	MG	KWH	KWH/MG	Lbs	KWH/Lb	KW	KW	KWH	KWH
Aug '23	2.02	62.74	108,300	1,726	142,542	0.76	222	231	12,127	130,327
Sep '23	2.53	75.95	120,600	1,588	134,488	0.9	192	201	10,113	118,413
Oct '23	2.16	67	105,300	1,572	134,616	0.78	195	213	10,331	131,493
Nov'23	2.07	62.06	104,700	1,687	43,777	2.39	195	201	13,297	115,631
Dec'23	2.79	86.49	129,300	1,495	66,318	1.95	207	234	15,313	117,997
Jan'24	3.18	98.54	135,600	1,376	48,027	2.82	261	273	18,956	144,613
Feb'24	2.9	84.23	122,400	1,453	122,094	1	213	231	21,708	154,556
Mar'24	3.58	110.89	111,000	1,001	128,077	0.87	222	216	16,633	144,108
Apr'24	3.4	101.85	143,700	1,411	158,901	0.9	228	237	17,451	127,633
May'24	2.61	81.03	112,800	1,392	155,428	0.73	210	219	16,066	161,151
Jun'24	2.03	61.01	116,100	1,903	151,206	0.77	186	222	12,509	128,866
Jul'24	1.46	45.28	123,000	2,716	137,028	0.90	186	195	10,930	133,930
Average	2.56	78.09	119,400	1,610	118,542	1.23	210	223	14,620	134,060

7.1 Work Order overview

WO Type	Total This Month	Total This Year
Preventative Maintenance	175	1,545
Corrective Maintenance	16	148
Emergency Call Outs Total	4	43

7.2 EMERGENCY CALL OUTS FOR THE MONTH

Туре	Total this Month	Total this Year
Sewer Back Up / Collection System	1	5
Pump Station	1	20
Plant	3	14
Odor	0	0
Power Outages	0	5
Total:	5	44

7.3 INSPECTIONS / ANNUAL PMS COMPLETED DURING THE MONTH

- 1. All pump station alarms checked
- 2. Eye wash inspections completed weekly
- 3. Fire extinguisher inspections completed monthly
- 4. Dependable Petroleum monthly UST Inspection


7.4 COLLECTION SYSTEM AND IPP ASSISTANCE PERFORMED BY VEOLIA

COLLECTION SYSTEM ASSITANCE:

Туре	Total This Month	Total This Year
Sewer Inspection / Tie-Ins	0	0
Sewer Location mark Outs	99	99
Sewer Back Up	0	0

7.5 WORK ORDER STATISTICS

There were 166.57 total reported maintenance hours during the month. Of this total, outside contractors accounted for 16% with **26** hours recorded.



8.0 Financial Accounting- Repair / Maintenance (July '24 – June '25)

Item	Budget	Spent Month	Spent Year	Remaining
R & M (Project)	\$100,000.00	\$11,665.80	\$11,665.80	\$88,334.20

8.1 SIGNIFICANT R&M PURCHASES

- 1. Soares Vactored and pumped out 3 pump stations \$4660.00
- 2. EIS installed ethernet at the back of the main control panel \$2,007.75
- 3. Grainger purchased a grinder pump for the tank cleanings \$2,689.96

9.0 ATTACHED REPORTS

- Discharge Monitoring Report
- HACH Wims Data Reports
- Financial Reports